



12.-13. November in Karlsruhe

energieinformatik2015



13 November 2015

Cyber Security Analysis of Smart Grid Communications with a Network Simulator

Roberta Terruggia and Giovanna Dondossola

RSE Ricerca sul Sistema Energetico

Milano ITALY



SMART C²NET

Agenda

The Medium Voltage Control use case & Medium Voltage testbed

Simulation model

- Communication
- DoS attack
- LTE mobile technology


Results

- Attack setup parameters
- Scaling up the model
- LTE model

Conclusion

DER (Distributed Energy Resource) forecast in MV grids: a realistic grid 2020 scenario

Distributed Generation on MV network



Source: ENEL, CIRED 2012

About 40 GW from installed renewables (PV/wind) connected to MV grids within 2020 in Italy

Connection rules (Norm CEI 0-16)


MV DER power

- $200 \text{ kW} < P_n < 6 \text{ MW}$ (mandatory)

Extended grid topology


- about 10% of new HV/MV substations

Medium Voltage Control



Based on SGSP Working Group Use
Case WGSP-0200 CEN / CENELEC /
ETSI

RSE PCS-ResTest Lab Layout



Focus: security of communications

Objective: run cyber security experiments over realistic VC scenarios

Technologies

- Data models
 - IEC 61850 Part 7
 - DER data models: IEC 61850 - 7 - 420
- Communication **protocols**
 - IEC 61850 Part 8-1 ed. 2 -> Manufacturing Message Specification (MMS)
- **Security** measures
 - End-to-end security -> IEC 62351-3 (TLS) ed.2
 - Monitoring -> IEC 62351-7
- Network **technologies**
 - Wired/wireless (Ethernet, LTE)

MV Control Test Bed



Grid and ICT Control Centres



Substation Control




DER Control




SNMP, NTP, PTP
IEC 60870-5-104
ACL, VPN, IPSEC

IEC 61850-7(-420)
IEC 61850-8-1
ACL, IEC 62351-3, TLS


Information Flows – RES measurements



IEC 61850 – MMS



The MMS View of Network Applications



The Common View of Network Applications

IEC 61850-8: Specific communication service mapping (SCSM) -> IEC 61850-8-1: Mappings to MMS

Manufacturing Message Specification ISO 9506

Application Level Protocol

Internationally standardized messaging system for the exchange of real-time data and supervisory control info


Independent of:

- the application function being performed
- the device vendor


Substation/DER communications

MMS Reports

MMS Setpoints



Focus of the simulation model



Network simulator: Why ns-3?

C++ (no Otlc)

IP address


Sockets

More interfaces per node

Packets contain real string of bytes

Integration of real source code -
application layer protocols

Pcap traces



ns-3: DCE framework

Direct Code Execution:

- Direct Code Execution (DCE) is a framework for ns-3 that provides facilities to **execute**, within ns-3, **existing implementations** of userspace and kernelspace network protocols or applications without source code changes.
 - Include MMS client / server testbed implementation
 - Include attack tools

ns-3 model

7 nodes



- Router nodes -> 2 NetDevices
- Server nodes -> 1 NetDevice

5 networks


- IP address

Measurements

- From DER Scada to MVGC
- TCP stack (TcpSocketFactory)
 - sink port 102
- Data rate 500 Kbps



Tools from the testbed



Testbed – Simulation alignment

Information flow

48	14.964851	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]	62	17.002374	10.1.1.1	10.1.3.1	MMS	unconfirmed-PDU
49	16.978357	192.168.1.43	158.47.121.32	MMS	179 unconfirmed-PDU	63	17.204617	10.1.3.1	10.1.1.1	TCP	49153-102 [ACK]
50	16.978454	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]	64	19.002374	10.1.1.1	10.1.3.1	MMS	unconfirmed-PDU
51	18.990947	192.168.1.43	158.47.121.32	MMS	179 unconfirmed-PDU	65	19.204617	10.1.3.1	10.1.1.1	TCP	49153-102 [ACK]
52	18.991044	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]	66	21.002374	10.1.1.1	10.1.3.1	MMS	unconfirmed-PDU
53	21.004561	192.168.1.43	158.47.121.32	MMS	179 unconfirmed-PDU	67	21.204617	10.1.3.1	10.1.1.1	TCP	49153-102 [ACK]
54	21.004657	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]	68	23.002374	10.1.1.1	10.1.3.1	MMS	unconfirmed-PDU
56	23.007143	192.168.1.43	158.47.121.32	MMS	179 unconfirmed-PDU	69	23.204617	10.1.3.1	10.1.1.1	TCP	49153-102 [ACK]
57	23.007238	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]	70	25.002374	10.1.1.1	10.1.3.1	MMS	unconfirmed-PDU
58	25.022732	192.168.1.43	158.47.121.32	MMS	179 unconfirmed-PDU	71	25.204617	10.1.3.1	10.1.1.1	TCP	49153-102 [ACK]
59	25.022828	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]	72	27.002374	10.1.1.1	10.1.3.1	MMS	unconfirmed-PDU
60	27.036353	192.168.1.43	158.47.121.32	MMS	179 unconfirmed-PDU	73	27.204617	10.1.3.1	10.1.1.1	TCP	49153-102 [ACK]
61	27.036449	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]	74	29.002374	10.1.1.1	10.1.3.1	MMS	unconfirmed-PDU
62	29.038935	192.168.1.43	158.47.121.32	MMS	179 unconfirmed-PDU	75	29.204617	10.1.3.1	10.1.1.1	TCP	49153-102 [ACK]
63	29.039028	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]						
64	31.052553	192.168.1.43	158.47.121.32	MMS	179 unconfirmed-PDU						
65	31.052653	158.47.121.32	192.168.1.43	TCP	66 35314 > iso-tsap [ACK]						

Testbed trace

Simulation trace

Testbed – Simulation alignment

Packet content


```
Frame 70: 179 bytes on wire (1432 bits), 179 bytes captured
Ethernet II, Src: Cisco_0a:76:61 (70:ca:9b:0a:76:61), Dst:
Internet Protocol Version 4, Src: 192.168.1.43 (192.168.1.4
Transmission Control Protocol, Src Port: iso-tsap (102), Ds
TPKT, Version: 3, Length: 113
ISO 8073/X.224 COTP Connection-Oriented Transport Protocol
ISO 8327-1 OSI Session Protocol
ISO 8327-1 OSI Session Protocol
ISO 8823 OSI Presentation Protocol
MMS
  unconfirmed-PDU
    unconfirmedService: informationReport (0)
      informationReport
        variableAccessSpecification: variableListName (1)
        listOfAccessResult: 9 items
          AccessResult: success (1)
            success: visible-string (10)
              visible-string: ID
          AccessResult: success (1)
            success: bit-string (4)
              Padding: 6
              bit-string: 4800
          AccessResult: success (1)
            success: unsigned (6)
              unsigned: 6
          AccessResult: success (1)
            success: visible-string (10)
              visible-string: ied1Inverter/LLN0$dataset1
          AccessResult: success (1)
            success: bit-string (4)
              Padding: 0
              bit-string: 0f
          AccessResult: success (1)
            success: structure (2)
              structure: 1 item
          AccessResult: success (1)
            success: structure (2)
              structure: 1 item
                Data: floating-point (7)
                  floating-point: 083fbd70a4
          AccessResult: success (1)
          AccessResult: success (1)
```

Testbed trace


```
Frame 66: 222 bytes on wire (1776 bits), 222 bytes captured (17
Ethernet II, Src: 00:00:00:00:00:06 (00:00:00:00:00:06), Dst: 0
Internet Protocol Version 4, Src: 10.1.1.1 (10.1.1.1), Dst: 10.
Transmission Control Protocol, Src Port: iso-tsap (102), Dst Po
TPKT, Version: 3, Length: 164
ISO 8073/X.224 COTP Connection-Oriented Transport Protocol
ISO 8327-1 OSI Session Protocol
ISO 8327-1 OSI Session Protocol
ISO 8823 OSI Presentation Protocol
MMS
  unconfirmed-PDU
    unconfirmedService: informationReport (0)
      informationReport
        variableAccessSpecification: variableListName (1)
        listOfAccessResult: 14 items
          AccessResult: success (1)
            success: visible-string (10)
              visible-string: ID
          AccessResult: success (1)
            success: bit-string (4)
              Padding: 6
              bit-string: 6900
          AccessResult: success (1)
            success: unsigned (6)
              unsigned: 4
          AccessResult: success (1)
            success: binary-time (12)
              binary-time: Jan 1, 2010 00:00:13.000000000 UTC
          AccessResult: success (1)
            success: visible-string (10)
              visible-string: ied1Inverter/LLN0$dataset1
          AccessResult: success (1)
            success: octet-string (9)
              octet-string: c8aa2ee725010000
          AccessResult: success (1)
            success: bit-string (4)
              Padding: 5
              bit-string: 0fe0
          AccessResult: success (1)
            success: structure (2)
              structure: 1 item
                Data: floating-point (7)
                  floating-point: 0840b99998
          AccessResult: success (1)
          AccessResult: success (1)
```

Simulation trace

Flooding Attack



Attack model: Flooding



UDP traffic generator

Source one or more attackers
(node 8 to node n)

Target the substation router (node 3).

ns-3 DCE: attack trace

Node 8..n -> RSE testbed flooding attack tool

- UDP packet size: parameter of the scenario
- Target-> router@substation


No.	Time	Source	Destination	Protocol	Length	Info
66	9.490018	10.1.1.1	10.1.3.1	MMS	222	unconfirmed-PDU
67	9.690041	10.1.3.1	10.1.1.1	TCP	64	49153 > iso-tsap [ACK] Seq=805 Ack=5497 win=65535 Len=0
68	11.490018	10.1.1.1	10.1.3.1	MMS	222	unconfirmed-PDU
69	11.690041	10.1.3.1	10.1.1.1	TCP	64	49153 > iso-tsap [ACK] Seq=805 Ack=5661 win=65535 Len=0
70	13.490018	10.1.1.1	10.1.3.1	MMS	222	unconfirmed-PDU
71	13.690041	10.1.3.1	10.1.1.1	TCP	64	49153 > iso-tsap [ACK] Seq=805 Ack=5825 win=65535 Len=0
72	15.490018	10.1.1.1	10.1.3.1	MMS	222	unconfirmed-PDU
73	15.690041	10.1.3.1	10.1.1.1	TCP	64	49153 > iso-tsap [ACK] Seq=805 Ack=5989 win=65535 Len=0
74	16.495988	00:00:00_00:00	Broadcast	ARP	64	who has 10.1.2.1? Tell 10.1.2.3
75	16.495988	00:00:00_00:00	00:00:00_00:00	CARP	64	10.1.2.1 is at 00:00:00:00:00:05
76	16.496006	10.1.2.3	10.1.2.1	UDP	146	Source port: ddi-udp-1 Destination port: interwise
77	16.496019	10.1.2.3	10.1.2.1	UDP	146	Source port: ddi-udp-1 Destination port: interwise
78	16.496032	10.1.2.3	10.1.2.1	UDP	146	Source port: ddi-udp-1 Destination port: interwise
79	16.496077	10.1.2.3	10.1.2.1	syslog	558	Attack UDP message from: NODE_4 to 10.1.2.1 : 514\0008\000\
80	16.496123	10.1.2.3	10.1.2.1	syslog	558	Attack UDP message from: NODE_4 to 10.1.2.1 : 514\0008\000\
81	16.496168	10.1.2.3	10.1.2.1	syslog	558	Attack UDP message from: NODE_4 to 10.1.2.1 : 514\0008\000\
82	16.496214	10.1.2.3	10.1.2.1	syslog	558	Attack UDP message from: NODE_4 to 10.1.2.1 : 514\0008\000\
83	16.496260	10.1.2.3	10.1.2.1	syslog	558	Attack UDP message from: NODE_4 to 10.1.2.1 : 514\0008\000\
84	16.496305	10.1.2.3	10.1.2.1	syslog	558	Attack UDP message from: NODE_4 to 10.1.2.1 : 514\0008\000\

ns-3: trace analysis

Simulation trace analysis


- Varying parameters
 - Number of attackers
 - Packet size
 - Packet rate
- Same indicators as testbed
 - Report RTT, retransmissions, losses ...

LTE mobile technology




HV/MV substation - DERs communication
by means of LTE technology

Ns-3 LTE communication model





Ns-3 LTE communication model




LTE connected attackers

Sensitivity analysis




Packet rate

Packet size




of attackers

Scaling up the model



LTE model



Conclusion

Simulation **model** of the **communications** and attacks for Voltage Control function in Smart Grid

Model aligned with the **testbed**

The attack scenarios modeling activity helps to **select more significant attack scenarios** to be demonstrate

- Varying the attack parameters for flooding attack:
 - Number of attackers
 - Packet size
 - Packet rate

Analysis of several scenarios **scaling up** the model size in order to demonstrate scenarios not feasible in the testbed

- Including the ns-3 LTE module
- Varying
 - the number of DERs
 - the number of attackers
 - LTE parameters

